

Appendix K: Rest Area Improvement Schedule

Region	Rest Area Name	Date of Site Visit	Phase	Summary	Completion Date	Work Order Number	Notes/Comments
1	Genessee Buffalo Herd	9/27/2016	B	ADA requires at least one van accessible parking space. Expand existing access aisle to 8' wide to accommodate vans or cars.			
			A	Raise accessible parking sign to 60"			
1	Georgetown Overlook	7/16/2016	C	Recommend an accessible route to information sign with a curb cut at the head of a designated (striped/painted) accessible parking space.			
2	Colorado City	8/4/2016	A	Raise existing parking signs to 80"			
			A	At current accessible parking, install directional sign on wall with ISA symbol and arrow pointing left			
			B	Create 2 new accessible parking spaces (1 van) to serve the west entrance with the more accessible ramp			
			C	Construct curb cut from new accessible parking spaces			
			C	Grind down both thresholds at exterior entrances so lip or edge is less than 1/4" or, if beveled, less than 1/2"			
			A	Wrap drain pipe under left-most sink in men's restroom			
			A	Install "family restroom" sign on wall on latch side of door			
			A	Make one 'ambulatory' stall in women's restroom by installing grab bars on both sides in women's restroom			
			C	Create a 48" wide landing on top of curb cut from RV/Truck parking area			

2	Gobbler's Knob	9/1/2016	A	If it is practical due to wind and environment, reduce door pressures at the two exterior restroom doors for easier opening		2000169804	
			A	Add a 'van' sign on vertical sign at the one accessible parking space		2000169804	
			B	Stripe 8' wide access aisle to right of the one accessible parking space		2000169804	
			B	Add Braille at Men's restroom sign		2000169804	
2	Holly	9/1/2016	B	Paint an access aisle between the two accessible parking spaces on south side; paint an access aisle between the two spaces on north side. Add a 'van' sign on vertical post at the accessible parking space on south side, on the east end.		2000179417	
			B	Add a grab bar on one side in the men's ambulatory restroom stall.			
			C	Add a full size accessible toilet stall in each restroom.			
2	Pueblo Pinon NB	6/19/2016	A	Add a restroom sign at 'family' restroom on wall, latch side of door.			
			A	Reduce door pressures at 3 restrooms to $\leq 5$ lbs.			
			A	Replace worn-out sign at men's restroom			
			A	Add 'van' to vertical post at one of accessible parking spaces			
2	Pueblo Pinon SB	6/19/2016	A	Reduce restroom door pressures to $\leq 5$ lbs of force			
			A	Add restrooms signs, raised letters and Braille, on wall, latch side of door at men's and women's restrooms.			

			A	At the two current accessible parking spaces on north side, install a vertical sign with ISA (International Symbol of Accessibility) at the head of each space. Add 'van' to one post.			
2	Trinidad/El Moro	10/5/2015		No remedies required			N/A
3	Bair Ranch	9/27/2016	B	Add access aisle next to one of the accessible parking spaces	4/20/2017	2000187274	
			A	Wrap sink pipes	4/20/2017	2000166378	
			B	Replace picnic table with one accessible picnic table	Done	N/A	Patrol Replaced
3	Edwards	9/28/2016	B	Create 8' access aisle between the 2 accessible parking spaces in northeast area			
			A	Add restroom signs, raised letters and braille, on wall, latch side of doors and men's, women's, and family restrooms	4/20/2017	2000187281	
			C	Create a curb cut sidewalk for an accessible path from truck/RV parking area			
3	Fruita	9/28/2016	A	Add vertical signs at the 2 accessible spaces on south end of lot	4/4/2017	2000179650	
			A	At one of the accessible parking spaces on east end, add 'van' to vertical post	4/4/2017	2000179650	

			A	Add restroom signs on wall on latch side of door	4/4/2017	2000179652	
			A	Wrap drain pipes under sinks	4/4/2017	2000179652	
			C	Construct full accessible toilet stall in both restrooms			
3	Grizzly Creek	9/27/2016	B	In parking area #1 - an access aisle is needed next to the accessible parking space.			
			C	In parking area #1 - grind down the 1.5" lip to sidewalk			
			A	In parking area #2 - the accessible parking space needs vertical sign and access aisle. Does have severe cross slope but no readily apparent solution.	5/10/2017	2000198566	
			B	In parking area #3 - paint an 8' access aisle for 'van' between the 2 designated accessible spaces. Add 2nd vertical sign.	5/15/2017	2000198529	
			A	Wrap sink pipes	4/20/2017	2000187264	
3	Hanging Lake	9/28/2016	A	Install vertical signs at 4 accessible parking spaces	5/15/2017	2000198531	
			A	Designate a 'van' space & add 'van' to vertical post.	5/15/2017	2000198531	
			C	Remove curb ramps from encroaching into access aisles			
			B	An access aisle is needed next to one of accessible parking spaces.	Done		
			A	Wrap sink pipes	5/15/2017	2000187274	
3	No Name	9/27/2016	A	Install another vertical sign at the second accessible parking space	4/27/2017	2000189072	
			B	Paint diagonal stripes in space next to the accessible parking space to indicate access aisle. Maintain 8' x 8' or 13' x 5' required dimensions			

			B	Add restroom signs on the wall, latch side of door, raised letters and Braille	4/20/2017	2000187242	
			B	An access aisle is needed next to one of the accessible parking spaces			
			A	Wrap sink pipes	4/20/2017	2000166389	
3	Rangely	9/28/2016	B/C	Add packed dirt/asphalt for a better ramp to restrooms.	N/A	N/A	N/A, This is not a CDOT rest area
			A	Add accessible restroom signs on wall at latch side of doors.	N/A	N/A	N/A, This is not a CDOT rest area
			C	Pave parking area and route to restrooms	N/A	N/A	N/A, This is not a CDOT rest area
3	Rifle	9/27/2016	B	Paint diagonal lines in access aisles Immediate			
			B	At one of the accessible parking spaces, expand access aisle to 8' and add 'van' to vertical post.	4/20/2017	2000187236	
			A	Add restroom signs on wall on latch side of door. Immediate	6/26/2017	2000217372	
			A	Wrap drain pipes under sinks/lavs Immediate	4/20/2017	2000187236	
3	Vail Pass	7/16/2016	A	Designate a 'van' space & add 'van' to vertical post.	4/20/2017	2000187293	
			B	Refresh faded paint at accessible parking spaces.			
			C	Pave small section of sidewalk that leads to accessible parking and ramp on north side	4/25/2017	2000188791	
			C	Construct a full-size accessible toilet stall in each restroom			
4	Arriba	9/1/2016	A	Reduce restroom door pressure to < 5 lbs of force			

			B	Add restroom signs, raised letters and braille, on wall, latch side of doors and men's and women's restrooms			
			B	At the two current accessible parking spaces on south side refresh faded paint and make access aisle 8'. Add "van" to one post			
4	Burlington	9/1/2016	B	Expand the landing at the west entrance to 60" x 60"			
4	Ft. Collins/Poudre	8/31/2016	A	Add restroom signs on wall on latch side of doors 60" high			
			C	Grind down 2" lip on concrete path to Welcome/Visitor Center			
4	Julesberg	9/17/2016	A	Add 'van' sign to post at space next to a large access aisle.			
			A	At family restroom add sign on latch side of door.			
4	Sterling	9/17/2016	B	One accessible parking space needs an adjacent access aisle			
			A	Add 'van' sign to post at space next to large access aisle			
			A	Add restroom signs on wall, latch side of door			
			C	Create accessible path to at least one picnic table			
			C	Create level landing at top of curb ramp from accessible parking			
4	Virginia Dale	8/31/2016	A	If it is practical due to wind and environment, reduce door pressures at the two exterior restroom doors for easier opening			
			A	Add vertical signs at head of accessible parking spaces			
			A	Add 'van' to one of the vertical signs			

			A	Wrap sink pipes			
4	Wiggins	9/17/2016	B	Enlarge one access aisle to 8' for 'van' and add 'van' sign to vertical post.			
			C	At family restrooms, add sign with raised letters and Braille on wall on latch side of door.			
			C	Create an accessible path to building from RV/Truck parking			
5	Cortex	10/5/2016	A	Install signs for all restrooms on wall on latch side of door	5/1/2017	2000188996	Issue addressed
			A	Wrap drain pipes under restroom sinks	5/1/2017	2000188996	Issue addressed
5	Shaw Creek	10/5/2016	A	Add two vertical parking sign posts with ISA			
			A	Add 'van' to one of the vertical accessible parking signs			
			A	Install signs for the restrooms on wall on latch side of door			
			B	Paint diagonal lines for an access aisle on west side			
			A	Reduce opening door pressure on restroom doors			
			A	Wrap drain pipes under restroom sinks			
			C	Construct a full size accessible toilet stall in each restroom			