

**CAMP GEORGE WEST &
COLORADO TRANSPORTATION MANAGEMENT CENTER
Golden, CO**



Summary Observations

An on-site ADA survey for Camp George West and the Colorado Transportation Management Center was conducted November 18, 2016, by Greg Martinez, CDOT ADA Title II Analyst/Coordinator, and Patrick Going, ADA Consultant. All observations are based on the *2010 ADA Standards for Accessible Design*. These Standards may be found at www.access-board.gov.

Camp George West is a multi-tenant location that includes three CDOT buildings. All of these buildings are ‘employee-only’ and not open to the public. **A survey is not required.** As a result, any accessibility issues would be dependent on ‘reasonable accommodations’ as enumerated in Title I of the ADA.

The Colorado Transportation Management Center (CTMC) is a two building complex in Golden, CO. The public may only visit the single building on the east.

The survey results that follow apply to the CTMC facility.

Parking

The parking lot has 38 spaces with two designated accessible parking spaces with one ‘van’ as required. The accessible parking space on the east end needs an adjacent 5’ access aisle.

Path-of-Travel

The route from the accessible parking spaces to the building is acceptable with the exception there is a 2” concrete lip that should be ground down to 1/2” or less.

Rest Rooms

The men’s and women’s rest rooms have adequate turning space and accessible elements. Restroom signs should be added to the wall on latch side of door. These signs need to have raised letters and Braille.

The pipes under the sinks need to be wrapped.

ADA Graded Summary *2010 ADA Standards for Accessible Design*






Excellent



Moderate



Poor



Parking	Route to Building	Restrooms
		
38 spaces/ 2 accessible with one ‘van’	Paved surface, has minor vertical lip, front doors are heavy.	Accessible. Minor concerns - additional signs needed on wall & sink pipes unwrapped.

Recommendations



Description	Priority
Paint access aisle at accessible parking space on east end of lot.	Soon
Raise accessible parking sign to 60"	Immediate
Grind down concrete lip on access route to entrance	Soon
Add restroom signs (raised letters and Braille) on wall, latch side of door.	Immediate
Wrap drain pipes under restroom sinks	Immediate



CDOT Buildings 'Employees' Only











Grind down lip



Good room signs w/ raised letters & Braille





With 2 or more urinals, one should be lowered to 17"



Wrap pipes

