

Ft. Collins/Poudre - I-25 MM 268
Elevation \approx 5000'



Summary Observations

An on-site ADA survey was conducted August 31, 2016, by Patrick Going, ADA Consultant. All observations are based on the *2010 ADA Standards for Accessible Design*. These Standards may be found at www.access-board.gov.

This is a relatively new rest area that is located 100 yards from a large Visitor/Welcome Center. It is very accessible to people with disabilities and is well maintained.

This rest area replaces two older areas, one northbound and one southbound, that were located right off I-25. Many Colorado maps currently available still indicate the older two areas and not this new site.

Parking

There are 47 parking spaces with four (4) designated accessible parking spaces. One of accessible spaces is 'van.'

There are additional parking areas for RV's and trucks at the nearby lot that also serves the Welcome/Visitor Center.

Path-of-Travel

The route from the current accessible parking spaces to the building is ADA compliant.

Rest Rooms

The men's, women's, and family restrooms are ADA compliant with the exception restroom signs need to be on the wall, on the latch side of the door at 60".

Vending Machines, Picnic Tables, and Visitor Information

There are no vending machines. The comprehensive Visitor/Information Center is approximately 100 yards away and has its own large parking lot. The picnic tables are accessible.

Dog Relief Areas

There are numerous areas for 'dog relief'.

ADA Graded Summary*

*Based on 2010 ADA Standards for Accessible Design







Excellent



Moderate




Poor

Parking 	Path-of-Travel to Building/Services 	Restrooms 	Vending/Picnic Tables 
Auto - 47 spaces/4 accessible. Truck and RV parking in a nearby separate area.	Paved surface, curb cuts, accessible slope	Women's, Men's , Family - ADA compliant	No vending machines. Picnic tables & pet areas accessible

Recommendations	
Description	Priority
Add restroom signs on wall on latch side of doors 60" high	Immediate
Grind down 2" lip on concrete path to Welcome/Visitor Center	Soon







Path between rest area building and Visitor Center



This 2" edge is on route from rest area to nearby Welcome/Visitor Center

