

**Rangely - SH 139 MM 55.9**  
**Elevation  $\approx$  5200'**

**CDOT Region #3**



## Summary Observations

An on-site ADA survey was conducted September 28, 2016, by Patrick Going, ADA Consultant. All observations are based on the 2010 ADA Standards for Accessible Design. These Standards may be found at [www.access-board.gov](http://www.access-board.gov).

This is a rural rest area with minimal improvements. It is maintained by the Bureau of Land Management (BLM).

## Parking

The parking area is an open area with a dirt and gravel surface. There are no lined parking spaces. The open parking area could probably handle 20 cars and RVs.

## Path-of-Travel

The route from the unpaved parking area to the restrooms is dirt which in wet weather would not be accessible (i.e. firm, stable, and slip resistant). There is a concrete lip and narrow sidewalk before the restroom doors that would make it difficult for a person using a wheelchair to manage independently.

## Rest Rooms

There is no running water or water for the toilets. The restrooms have a pit toilet with adequate maneuvering space.

The restroom signs do not have raised letters or Braille. They are located in the correct location however.

## Vending Machines and Visitor Information

No vending machines. There are several information boards, but the path to them is dirt and gravel.

## Dog Relief Areas

The whole surrounding area is a 'dog relief' area.



## ADA Graded Summary\*

\*Based on 2010 ADA Standards for Accessible Design



Excellent



Moderate



Poor

Parking	Path-of-Travel to Building/Services	Restrooms	Picnic Table
The parking area is dirt and gravel with no marked parking spaces	All the paths are dirt and gravel. Concrete lip to restrooms.	<b>Women's</b> - new sign with raised letters and Braille  <b>Men's</b> - new sign with raised letters and Braille	Picnic table not accessible Pet area - OK

Recommendations	
Description	Priority
Add packed dirt/asphalt for a better ramp to restrooms.	Immediate
Add accessible restroom signs on wall at latch side of doors.	Soon
Pave parking area and route to restrooms	Future





Visitor Information Boards

