

Summary Observations

An on-site ADA survey was conducted September 27, 2016, by Patrick Going, ADA Consultant. All observations are based on the 2010 ADA Standards for Accessible Design. These Standards may be found at www.access-board.gov.

This is a modern rest area that includes a Visitor Center - which was closed for remodeling at the time of this visit. There is also an accessible wildlife viewings.

This rest area is accessible for people with disabilities though there are a few corrections needed in the parking areas.

Parking

With a total of 59 automobile parking spaces, the six (6) designated accessible parking spaces for automobiles exceed the minimum ADA scoping requirements (1:25). However, there is a requirement that 1:6, but no less than one, of the accessible spaces be a 'van' space. There are access aisles next to the accessible parking spaces and in order to provide the 'van' space, there is room to expand one of the access aisle to 8'. The required diagonal striping needs to be painted in all the access aisles.

There is a separate parking area for RV's and trucks. Although there is not a designated accessible parking space for trucks or RVs, a curb cut is provided for access to the building.

Path-of-Travel

The route from the accessible parking spaces to the building is acceptable.

Rest Rooms

The restrooms and toilet stalls are accessible with adequate maneuvering space, grab bars, and other compliant elements. The doors do have a power assist option which is most helpful as the doors open to the outside weather. The restroom signs are mounted the doors so additional signs are needed for the wall on the latch side of the door. The new signs need to have raised letters and Braille.

The pipes under the sinks/lavs are not wrapped.

Vending Machines and Visitor Information

There are no outside vending machines. There is a Visitor Center that is currently being remodeled.

Dog Relief Areas and RV/Trailer Dump

There are numerous designated 'dog relief' areas. Most are accessible for people with assistive mobility devices. The 'trailer dump' is accessible.

ADA Graded Summary*

*Based on 2010 Standards for Accessible Design



Excellent



Moderate




Poor

Parking	Path-of-Travel to Building/Services	Restrooms	Vending/Picnic Tables
			
59 spaces/6 accessible. No 'van' space indicated.	Paved surface, curb cuts, OK slope	Women's & Men's OK	No Vending Machines Picnic tables - OK Pet area - OK

Recommendations	
Description	Priority
Paint diagonal lines in access aisles	Immediate
At one of the accessible parking spaces, expand access aisle to 8' and add 'van' to vertical post.	Immediate
Add restroom signs on wall on latch side of door.	Immediate
Wrap drain pipes under sinks/lavs	Immediate









Wildlife Viewing