



Bustang ADA Survey Checklist

Location: Eagle Chambers Park and Ride

Date: September 28, 2016

Survey Conducted By: Patrick Going, ADA Consultant

<i>Parking & Drop-Off Area</i> No Parking Specifically for Bustang Provided	-	-
--	---	---

COMMENTS: There is a nearby parking area on north end with five spaces for customers of Loaf & Jug. Not available long-term.

<i>Exterior Path-of-Travel to Bustang Loading Area</i>	YES	NO
<i>Is the walkway to the bus loading area paved, relatively flat, and free of abrupt edges or breaks in the surface?</i>	X	
<i>Are all curbs along walkway ramped?</i>	X	
<i>Are stairs or steps along the walkway either ramped or have alternative means of access (e.g. elevator)?</i>	X	
<i>Is the walkway/hallway 36" minimum width and free of protrusions or overhanging obstacles?</i>	X	

COMMENTS: Like all the Bustang stops, larger signs are recommended.

<i>Bustang Bus Waiting Shelter</i>	YES	NO
<i>Is the shelter on an accessible route with adequate clearance to enter and accessible benches (if provided).</i>	X	

<i>Restrooms</i>	YES	NO
<i>If restrooms provided, is there an accessible restroom (signage, doors pressure <5 lbs, toilet height, grab bars, accessible sink)?</i> No restrooms specifically for Bustang or local transportation buses.	-	

COMMENTS: Restrooms are available at nearby Loaf & Jug convenience store.

<i>Local Connecting Transportation</i>	YES	NO
<i>Is public transportation available? ECO Transit</i>	X	
<i>Local bus stop less than 1/4 mile to Bustang loading area?</i>	X	
<i>Is route from local bus stop to Bustang stop accessible? (Will be once construction complete)</i>	X	

<i>Other</i>	YES	NO
<i>Ticket counter accessible (if provided)? No higher than 36".</i> N/A - pay on bus	-	
<i>Rider information (schedules, fares, etc.) properly displayed and available in large print or alternate format?</i> Schedule was not on display in bus shelter	-	





Suggest a larger sign to ID Bustang stop