


INITIALS	DESIGN	DATE	DETAIL	DATE	QUANTITY	DATE
By						
Checked By						

INITIALS	DESIGN	DATE	DETAIL	DATE	QUANTITY	DATE
By						
Checked By						




1. Payment will be made under item 606, Transition Type BR9-GR9, consisting of Concrete Class DF, reinforcing steel, concrete sealer, standard galvanized pipes, dowels, and expansion joint material. The poured joint, expansion joint material, excavation and backfill will not be paid for separately, but shall be included in the work.
2. Rails shall be constructed tapering perpendicular to bridge cross slope (bridge rail side) to plumb (3G/3H side). Vertical dimensions are perpendicular to the longitudinal roadway grade.
3. The top and inside face of the transition rail shall receive a coating conforming to Item 515, Concrete Sealer, compatible with the concrete coating/stain shown in the plan.
4. Concrete and reinforcing steel shall conform to the requirements of Section 601 & 606 and 602 respectively unless otherwise noted.
5. All longitudinal reinforcement shall terminate with standard stirrup hooks as shown. Rotate or adjust reinforcing hooks to avoid interferences as required.

Concrete: Class DF       $f'_c = 4.5$  KSI  
Reinforcing Steel:       $f_y = 60$  KSI Min  
All reinforcing bends shall use a 4D pin diameter.

Designer/Detailer: Any changes to barrier shape or reinforcing shall be approved by Staff Bridge.

Description	Unit	Quantity
Structural Steel (Galvanized)	LB	23
Concrete Sealer	SY	3.5
Concrete Class DF	CY	1.3
Reinforcing Steel (Epoxy Coated)	LB	239

Note: Reinforcing dimensions and quantities given for 3" overlay



- ▲ 2" Deep poured joint filler, polysulfide or silicone sealant. Extend up to sidewalk and 6" up face of rail curb.
- \* Utility as shown in Plans

All seals for this set of drawings are applied to the cover page(s)	Print Date: \$DATE\$	<div><div></div><div></div><div></div><div></div><div></div></div>	Sheet Revisions			Colorado Department of Transportation		As Constructed		TRANSITION TYPE BR9-GR9 SLEEPER VERSION				Project No./Code	
	File Name: Sheet_B-606-9B.dgn		Date:	Comments	Init.	<div><div></div><div>2829 West Howard Place, 3rd Floor Denver, CO 80204 Phone: 303-512-4079 FAX: 303-757-9197</div></div> <div>Staff Bridge Branch</div> <div>Initials</div>	No Revisions:						Project Number		
	Horiz. Scale: None      Vert. Scale: As Noted						Revised:		Designer:    XXXXXXXX    Structure:    X-XX-XX Detailer:    XXXXXXXX    Numbers:    X-XX-XX		Code				
	Unit Information      Unit Leader Initials						Void:		Sheet Subset:    BRIDGE    Subset Sheets: BXX of XXX		Sheet Number				