

Sidewalk

€ Post

1'-6"

TYPICAL SECTION

- 1. Fence assembly shall be galvanized after fabrication. If vinyl coating is specified, the fence assembly shall be galvanized and vinyl coated after fabrication. Anchorages shall only be galvanized after fabrication.
- 2. Truss rods shall have turnbuckles.
- 3. Posts shall be vertical. Horizontal pipes shall be bent if radius is 100' or less and may be on chords between posts if radius is greater than 100'.
- 4. Pipe shall conform to ASTM A53 Type E or S, Grade B fy = 35,000 psi.
- 5. Alternative details may be submitted by Contractor for Engineer's approval.

No.			
7YR 2.4/1.75			
8.8G 2.63/5.8			

Special Color Vinyl Coatings □Federal Color No
□Munsell Color System No over Galvanized Wire

If the specific color of coating is not marked and the Federal Color No or the Munsell Color System No is not given, vinyl coating is not required.

All seals for this set of drawings are applied to the cover page(s)

Print Date: \$DATE\$				Sheet Revisions	
File Name: Sheet_B-607-6B.dgn			Date:	Comments	Init.
Horiz. Scale: None	Vert. Scale: As Noted				
Unit Information	Unit Leader Initials	\bigcup			
		\bigcup			

Colorado Department of Transportation 2829 West Howard Place, 3rd Floor

Denver, CD 80204 Phone: 303-512-4079 FAX: 303-757-9197 Staff Bridge Branch **Initials**

	As Constructed	F	Project No./Code			
	No Revisions:	(S	Project Number			
	Revised:		XXXXXXX	Structure Numbers		Code
s	Void:	Detailer: Sheet Subset:	^^^^		X-XX-XX eets: BXX of XXX	Sheet Number

3/99 11/99 5/00 4/02 3/07 10/13 3/23 9/