REVISION OF SECTION 630 METHOD OF HANDLING TRAFFIC

Section 630 of the Standard Specifications is hereby revised for this project as follows:

In subsection 630.09 (8), delete Table 630-2 and replace with the following:

Table 630-2 VERTICAL CLEARANCES TO STRUCTURES

| | Highway | Railway | |
|--|----------------------|----------------------|-----------------------|
| | Underpasses | Underpasses | Overhead Wires |
| Local Rural Roads Local Urban Streets Rural Collectors Urban Collectors | 14 Feet | 23 Feet ² | 3 |
| Rural Arterial Urban Arterial Freeways | 16 Feet ¹ | 23 Feet ² | 3 |
| Vertical clearance to sign trusses and pedestrian overpasses shall be 17 feet. Measured from top of rail to bottom of highway structure. All railway clearances are subject to the individual railroad's approval. Communication and power lines of: 0 to 750 volts 18 Feet 750 to 22,000 volts 20 Feet 22,000 to 50,000 volts 22 Feet For voltages over 50,000 volts, increase clearance ½ inch for each 1000 volts. | | | |